

TANK PUMPING REPORT

9/18/2018

Site Name:

Location: 6755 BIRDSEYE VIEW LOOP NW
Seabeck
Tax ID: 26250230441009

Use:

Service Company:

KITSAP SEPTIC PUMPING

5201 E. Hillcrest Dr.
Port Orchard, WA 98366
360.871.5258

Serviced:09/10/2018 by: Austin Lowe

Submitted 09/11/2018 by:Darren Miller

Dump Location: Bio-Recycling

Jurisdiction ID:2513240:0

COMMENTS

Pumped and inspected for sale of home

TANK: Septic Tank - 1 Compartment

All riser lids securely fastened upon departure	N/A	
Tank Pumped:	YES	
Tank Size (Gallons)(Number only, no text):	1000	
Effluent level within operational limits (if NO explain in comments):	YES	
Total Gallons pumped from tank (Number only, no text):	1000	
Effluent returning back into tank after pumping:	NO	
Tank depth below grade (inches):	18	
Access Risers installed to grade (N/A if not present):	NO	
Tank Construction Material:	Concrete	
Tank Condition Good:	YES	
Baffles in good condition (N/A if not present):	YES	
Effluent screen cleaned (N/A if not present):	N/A	
Effluent surfacing around site components (N/A if not checked):	NO	
Tank abandoned after pumping:	NO	
Were repairs made to the Tank or Tank Components? (if YES explain in comments):	NO	
Compartment 1 Scum accumulation (Inches, if other specify):	16	
Compartment 1 Sludge accumulation (Inches, if other specify):	10	

This report indicates certain characteristics of the onsite sewage system at the time of visit. In no way is this report a guarantee of operation or future performance.